# Agenda Item Form

Districts Affected: #1 Dept. Head/Contact Information: Irene Ramirez, P.E., Interim City Engineer Ext. 4422/Bashar Abugalyon, P.E., Interim Assistant City Engineer Ext. 4157 Type of Agenda Item: Resolution ☐ Staffing Table Changes ☐Board Appointments Tax Installment Agreements ☐Tax Refunds □Donations RFP/ BID/ Best Value Procurement ☐Budget Transfer ☐Item Placed by Citizen ☐ Application for Facility Use ☐Bldg. Permits/Inspection ☐Introduction of Ordinance ☐Interlocal Agreements ☐ Contract/Lease Agreement ☐ Grant Application Funding Source: General Fund Grant (duration of funds: \_\_\_\_\_ Months) Other Source: Legal: Legal Review Required Attorney Assigned (please scroll down): None ☐ Approved Denied Timeline Priority: ☐High Medium □Low # of days:\_\_\_ Why is this item necessary: Requested by: Colony Partners L.P. Explain Costs, including ongoing maintenance and operating expenditures, or Cost Savings: No costs **Statutory or Citizen Concerns:** In accordance with Chapter 19.32 Inspection and Acceptance of Improvements: Franklin Hills Unit Two Departmental Concerns: Department recommends approval

Agenda Date: June 2, 2004

### ENGINEERING DEPARTMENT

TO:

CITY CLERK

DATE: April 13, 2004

FROM:

LUCY MCGEE

4<sup>th</sup> Floor

4970/4441

Telephone/Fax Number

Please place the following item on the CONSENT Agenda for the Council Meeting of June 2, 2004. Item should read as follows:

Request that the street and drainage improvements in the following subdivision to be accepted for maintenance by the City. The improvements within the stated limits have been completed in accordance with the approved plans and specifications.

Subdivision:

Franklin Hills Unit Two

Owner/Developer:

Colony Partners L.P.

Consultant:

Quantum Inc.

# Street Improvements:

High Ridge Drive.-from the west subdivision boundary line to the east subdivision boundary line

Franklin Crest Drive.-from the north R.O.W. line of High Ridge Drive to the northt subdivision boundary line

Franklin Hills Street.-from the north subdivision boundary line to the southwest subdivision boundary line

Franklin View Drive.-from the east R.O.W. line of Franklin Cove Place to the west R.O.W. line of Franklin Crest Drive, and from the east R.O.W. line of Franklin Crest Drive to the northeast subdivision boundary line

Franklin Cove Place.-from the north R.O.W. line of High Ridge Drive to the end of culde-sac

Franklin Summit Drive.-from the east subdivision boundary line to the east R.O.W. line of Franklin Crest Drive, and from the west R.O.W. line of Franklin Crest Drive to the end of cul-de-sac

Franklin Nook Way.-from the north R.O.W. line of Franklin Summit Drive to the end of cul-de-sac

Franklin Trail Drive.-from the north R.O.W. line of Franklin Summit Drive to the west R.O.W. line of Franklin Hills Street

Franklin Vista Drive.-from the east R.O.W. line of Franklin Trail Drive to the east subdivision boundary line

Franklin Bluff Drive.-from the east R.O.W. line of Franklin Trail Drive to the east subdivision boundary line

Franklin Red Drive.-from the east R.O.W. line of Franklin Crest Drive to the west R.O.W. line of Franklin Hills Street

# Drainage Improvements:

15 ft. Drainage Easement.-located at Lot 3, Block 12; 130 ft. of 2-36" R.C.P. with Concrete Collars

15 ft. Drainage Easement.-located at Lot 8, Block 17; 105.67 ft. of 24" R.C.P. with Concrete Collars

15 ft. Drainage R.O.W. located between Lots 7 and 8, Block 16; 47.50 ft. of 30" R.C.P. with Concrete Collars; 20.77 ft. x 14 ft. Concrete Flume; 41.54 ft. x 6 ft. high Rock Wall Fence located at the east and west sides of the R.O.W.; and 15 ft. x 6 ft. Wrought Iron Gate

Drainage R.O.W. Concrete Channel.-from Station 0 + 00 to Station 17 + 10.48; 1710.48 ft. of Reinforced Concrete Channel that varies in dimension; 2- 78 ft. x 8 ft. x 4 ft. Reinforced Concrete Box Culvert; 65 ft. of 24" R.C.P. Concrete Spillway; Berm; 1434.71 ft. x 6 ft. high Rock Wall Fence along the Concrete Channel; 90 ft. x 3 ft. high Rock Wall Fence; 90 ft. x 4 ft. high Wrought Iron Fence; 2- 15 ft x 6 ft. Double Swing Gate; and 2-15 ft. Concrete Apron

Storm Drainage System.-located at Franklin Cove Place; 1-6 Grate Drop Inlet Type III; and 251.41 ft. of 30" R.C.P.

located at Franklin Summit Drive; 1-10 Grate Drop Inlet Type I; and 1-4 Grate Drop Inlet Type I

located at Franklin Trail Drive; 2-5 Grate Drop Inlet Type I; 34.7 ft. of 24" R.C.P.; and 140.20 ft. of 36" R.C.P.

located at Franklin Crest Drive; 8 ft. x 9 ft. Concrete Flume with Steel Plate and Rock Rip-Rap

[Engineering Department, Bashar Abugalyon, P.E., Interim Assistant City Engineer at 541-4157]

District 1

ENGINEERING DEPARTMENT	AGENDA ITEM SUMMARY	MEETING: JUNE 2, 2004
DEPT: ENGINEERING		AGENDA: CONSENT
NUMBER AND/OR AMOUNT:		DIST: # 1 REP: Susan Austin
SUBJECT:	ACCEPTANCE OF STREET A	AND DRAINAGE IMPROVEMENTS
SURDIVISION .	Franklin	n Hills Unit Two

#### TEXT OF ITEM:

Request that the street and drainage improvements in the following subdivision to be accepted for maintenance by the City. The improvements within the stated limits have been completed in accordance with approved plans and specifications

Subdivision: Franklin Hills Unit Two Owner / Developer: Colony Partners L.P. Consultant: Quantum Inc.

> Irene Ramirez, P.E. Interim City Engine

#### DESCRIPTION OR EXPLANATION:

#### STREET IMPROVEMENTS:

High Ridge Drive. - from the west subdivision boundary line to the east subdivision boundary line

Franklin Crest Drive. - from the north right-of-way line of High Ridge Drive to the north subdivision boundary line

Franklin Hills Street. - from the north subdivision boundary line to the south subdivision boundary line

Franklin View Drive. - from the east right-of-way line of Franklin Cove Place to the west right-of-way line of Franklin Crest Drive, and from the east right-of-way line of Franklin Crest Drive to the east subdivision boundary line

Franklin Cove Place. - from the north right-of-way line of High Ridge Drive to the end of cul-de-sac

Franklin Summit Drive. - from the east subdivision boundary line to the east right-of-way line of Franklin Crest Drive, and from the west right-of-way line of Franklin Crest Drive to the end of cul-de-sac

Franklin Nook Way. - from the north right-of-way line of Franklin Summit Drive to the end of cul-de-sac

Franklin Trail Drive. - from the north right-of-way line of Franklin Summit Drive to the west right-of-way line of Franklin Hills Street

Franklin Vista Drive. - from the east right-of-way line of Franklin Trail Drive to the east subdivision boundary line

Franklin Bluff Drive. - from the east right-of-way line of Franklin Trail Drive to the east subdivision boundary line

Franklin Red Drive. - from the east right-of-way line of Franklin Crest Drive to the west right-of-way line of Franklin Hills Street

### DRAINAGE IMPROVEMENTS:

15 ft. Drainage Easement. - located at Lot 3, Block 12; 130 ft. of 2-36" R.C.P. with Concrete Collars

15 ft. Drainage Easement. - located at Lot 8, Block 17; 105.67 ft. of 24" R.C.P. with Concrete Collars

15 ft. Drainage R.O.W. - located between Lots 7 and 8, Block 16; 47.50 ft. of 30° R.C.P. with Concrete Collars; 20.77 ft. x 14 ft. Concrete Flume; 41.54 ft x 6 ft. high Rock Wall Fence located at the east and west sides of the R.O. W.; and 15 ft. x 6' Wrought Iron Gate

ENGINEERING DEPARTMENT FOR INFORMATION CONTACT BASHAR ABUGALYON, P.E. AT 541-4157

ENGINEERING DEPARTMENT AGENDA ITEM SUMMARY	MEETING: June 2, 2004				
DEPT: ENGINEERING	AGENDA: CONSENT				
NUMBER AND/OR AMOUNT:	DIST: # 1 REP: Susan Austin				
SUBJECT: ACCEPTANCE OF STREET AND DRAINAGE IMPROVEMENTS					
SUPPRISION : Franklin H	Hills Unit TWO				

#### TEXT OF ITEM:

Request that the street and drainage improvements in the following subdivision to be accepted for maintenance by the City. The improvements within the stated limits have been completed in accordance with approved plans and specifications

Subdivision: Franklin Hills Unit Two
Owner / Developer: Colony Partners L.P.
Consultant: Quantum Inc.

Irene Ramirez, P.E. Interim City Engineer

#### **DESCRIPTION OR EXPLANATION:**

## DRAINAGE IMPROVEMENTS: ( Continued )

Drainage R.O.W. Concrete Channel. - from Station 0+00 to Station 17+10.48; 1710.48 ft. of Reinforced Concrete Channel that varies in dimension;
2- 78 ft. x 8 ft. x 4 ft. Reinforced Concrete Box Culvert; 65 ft. of 24" R.C.P. Concrete Spillway and Berm; 3316 ft. x 6 ft. high Rock
Wall Fence along the Concrete Channel; 90 ft. x 3 ft. high Rock Wall Fence; 90 ft. x 4 ft. high Wrought Iron Fence; 2- 15 ft x 6ft high Double
Swing Gate; and 2- 15 ft. Concrete Apron

#### Storm Drainage System. •

located at Franklin Cove Place; 1-6 Grate Drop Inlet Type III; and 251.41 ft. of 30" R.C.P.

located at Franklin Summit Drive; 1-10 Grate Drop Inlet Type I; and 1-4 Grate Drop Inlet Type I

located at Franklin Trail Drive; 2-5 Grate Drop Inlet Type I; 34.7 ft. of 24" R.C.P.; and 140.20 ft. of 36" R.C.P.

located at Franklin Crest; 8 ft. X 9 ft. Concrete Flume with Steel Plate and Rock Rip-Rap

# Acceptance for Maintenance Report Street Improvements

	·	
SUBDIVISION:	Franklin Hills Unit Two	In accordance with the "Subdivision Ordinance
OWNER/DEVELOPR:	Colony Partners L.P.	the following public improvements have been
CONSULTANT:	Quantum Inc.	constructed and installed, therefore acceptance
REP/DIST:	Susan Austin - District #1	for maintenance is hereby endorsed.

STREET NAME	PROM / TO	ROAD IMPROV LGTH x WDTH	CURB TYPE	INLET TYPE / GRATES	FLUME/ RW/SW	PAVEMENT DESIGN HMAC BASE SG
High Ridge Drive	from the west subdivision boundary line to the east subdivision boundary line	939.88' x 56.00'	Curb &		244' x 4' RW; &	2.5" H.M.A.C.
			Gutter		940' x 5' SW	8.0" Base & 10.0" S.G.
Franklin Crest Drive	from the north right-of-way line of High Ridge Drive to the north subdivision	1706.60' x 36.00'	Curb &		8' x 9' Concrete	1.5" H.M.A.C.
	boundary line		Gutter		Flume	6.0" Base & 8.0" S.G.
Franklin Hills Street	from the north subdivision boundary line to the south subdivision boundary line	525.27' x 44.00'	Curb &			2.0" H.M.A.C.
			Gutter			8" Base & 10" S.G.
Franklin View Drive	from the east right-of-way line of Franklin Cove Place to the west right-of-way	860.48' × 36.00'	Curb &			1.5" H.M.A.C.
	line of Franklin Crest Drive, and from the east right-of-way line					
	of Franklin Crest Drive to the east subdividion boundary line.		Gutter			6.0" Base & 8.0" S.G.
Franklin Cove Place	from the north right-of-way line of High Ridge Drive to the end of cul-de-sac	453.19' x 36.00'	Curb &	1-6 Gt. D.I.		1.5" H.M.A.C.
			Gutter	Type III		6.0" Base & 8.0" S.G.
Franklin Summit Drive	from the east subdivision boundary line to the east right-of-way line of Franklin Crest Drive,	1108.1' x 36.00'	Curb &	1-10 & 1-4 Gt. D.I		1.5" H.M.A.C.
	and from the west right-of-way line of Franklin Crest Drive to the end of cul-de-sac		Gutter	Type I		6.0" Base & 8.0" S.G.

OMAR K. SOUEIDAN, CE II Construction Engineer

Original to: City Clark

Copies to:

Mayor & Representatives
Chief Administrative Officer
Exec. Assistant to the Mayor
City Attorney
Assistant City Attorney
Director of Public Works

Deputy Director for Engineering
Deputy Director for Streets
Deputy Director for Building Services
Engineering Section Chief- Traffic Division
Planning Department - Subd. Coordinator

antono Buttle

for BASHAR ABUGALYON, P.E.
Interim Assistant City Engineer

# Acceptance for Maintenance Report Street Improvements

In accordance with the "Subdivision Ordinance"

the following public improvements have been

constructed and installed, therefore acceptance

Interim Assistant City Engineer

SUBDIVISION: Franklin Hills Unit Two

OWNER/DEVELOPR: Colony Partners L.P.

CONSULTANT: Quantum Inc.

REP/DIST: Susan Austin - District #1 for maintenance is hereby endorsed.

STREET NAME	PROM/TO	ROAD IMPROV	CURB TYPE	INLET TYPE / GRATES	5.5 (A. C.	
Franklin Nook Way	from the north right-of-way line of Franklin Summit Drive to the end of cul-de-sac	328.44' x 36.00'	Curb &			1.5" H.M.A.C.
			Gutter			6.0" Base & 8.0" S.G.
Franklin Trail Drive	from the north right-of-way line of Franklin Summit Drive to the west right-of-way line of Fr	1695.73' x 36.00'	Curb &	2-5 Gt. D.I.		1.5" H.M.A.C.
	Hills Street		Gutter	Type I		6.0" Base & 8.0" S.G.
Franklin Vista Drive	from the east right-of-way line of Franklin Trail Drive to the east subdivision boundary line	88.00' x 36.00'	Curb &			1. <b>5"</b> H.M.A.C.
			Gutter			6.0" Base & 8.0" S.G.
Franklin Bluff Drive	from the east right-of-way line of Franklin Trail Drive to the east subdivision boundary line	88.00' x 36.00'	Curb &			1.5" H.M.A.C.
			Gutter			6.0" Base & 8.0" S.G.
Franklin Red Drive	from the east right-of-way line of Franklin Crest Drive to the west right-of-way line of Frankl	1083.93' x 36.00'	Curb &			1.5" H.M.A.C.
	Street		Gutter			6.0" Base & 8.0" S.G.

OMAR K. SOUEIDAN, CE II
Construction Engineer

Original to: City Clerk

Copies to:

Mayor & Representatives
Chief Administrative Officer
Exec. Assistant to the Mayor
City Attorney
Assistant City Attorney

Director of Public Works

Deputy Director for Engineering
Deputy Director for Streets
Deputy Director for Building Services
Engineering Section Chief- Traffic Division
Planning Department - Subd. Coordinator

autono Bertitles

# Acceptance For Maintenance Report **Drainage Improvements**

SUBDIVISION:

Franklin Hills Unit Two

In accordance with the "Subdivision Ordinance"

OWNER/DEVELOPR:

Colony Partners L.P.

the following public improvements have been

CONSULTANT:

Ouantum Inc.

constructed and installed, therefore acceptance for maintenance is hereby endorsed.

REP/DIST:

Susan Austin - District #1

**DETENTION / RETENTION** POND AREA FENCE LENGTH & TYPE STORM SEWER STORM DRAINAGE SYSTEM AREAS IN ACRE INLETS AT **OUTLETS TO** LENGTH, SIZE & TYPE CHAINLINK/ROCKWALL WROUGHT IRON CAPACITY IN ACRE FT. 15 ft. Drainage Easement at Lot 3, 130 ft. of 2-36" R.C.P. with Concrete Collars Block 12 15 ft. Drainage Easement at Lot 8, 105.67 ft. of 24" R.C.P. with Concrete Collars Block 17 15 ft. Drainage R.O.W. Between 47.50 ft. of 30" R.C.P. with Concrete Collars; and 41.54 ft. x 6 ft. high Rock Wall Fence located at the east and west sides of Lots 7 & 8, Block 16 20.77 ft. x 14 ft. Concrete Flume R.O.W.; and 15 ft. Wrought Iron Gate Drainage R.O.W. Concrete Channel 1710 ft. of Reinforced Concrete Channel that varies 3316 ft. x 6 ft. high Rock Wall Fence along the Concrete Channel; from Station 0+00 to Station 17+10.48 in dimension; 2-78 ft. x 8 ft. x 4 ft. Reinforced 90 ft. x 3 ft. Rock Wall Fence; 90 ft. x 3 ft. Wrought Iron Fence; 2- 15 ft. Concrete Box Culvert; 65 ft. of 24" R.C.P.; and Double Swing Gates; and 2-15 ft. Concrete Aprons Concrete Spillway and Berm

antomo Bustilles antomo Bustelles

Original to: City Clerk

Copies to:

Mayor & Representatives Chief Administrative Officer Exec. Assistant to the Mayor City Attorney Assistant City Attorney Director of Public Works

Deputy Director for Engineering Deputy Director for Streets Deputy Director for Building Services Engineering Section Chief- Traffic Division Planning Department - Subd. Coordinator

# Acceptance For Maintenance Report Drainage Improvements

SUBDIVISION: Franklin Hills Unit Two

OWNER/DEVELOPR: Colony Partners L.P.

CONSULTANT: Quantum L.P.

REP/DIST: Susan Austin - District #1

In accordance with the "Subdivision Ordinance"

the following public improvements have been

constructed and installed, therefore acceptance

for maintenance is hereby endorsed.

DETENTION / RETENTION STORM DRAINAGE SYSTEM	POND AREA AREAS IN ACRE CAPACITY IN ACRE FT.	INLETS AT	OUTLETS TO	STORM SEWER LENGTH, SIZE & TYPE	FENCE LENGTH & TYPE CHAINLINK / ROCKWALL WROUGHT IRON
Storm Drainage System		Franklin Cove Place	Channel	1-6 Gt. D.I. Type III; and 251.41 ft. of 30" R.C.P.	
		Franklin Summit Drive	Channel	1-10 Gt. D.I. Type I; and 1-4 Gt. D.I. Type I	
		Franklin Trail Drive	Channel	2-5 Gt. D.I. Type I; 34.7 ft. of 24" R.C.P.; and 140.20 ft.	
				36" R.C.P.	

OMAR K. SOUEIDAN, CE II

Construction Engineer

ke

BASHAR ABUGALOYN, P.E. Interim Assistant City Engineer

autom Bustille

Original to: City Clerk

Copies to:

Mayor & Representatives
Chief Administrative Officer
Exec. Assistant to the Mayor
City Attorney
Assistant City Attorney
Director of Public Works

Deputy Director for Engineering
Deputy Director for Streets
Deputy Director for Building Services
Engineering Section Chief-Traffic Division
Planning Department - Subd. Coordinator

4487 Mesa, Suite 201 El Paso, Texas 79902 533-7900 Fax: 533-7926

March 3, 2004 Revised May 2, 2004

Mr. Omar Soueidan City Engineering Department 2 Civic Center Plaza El Paso, Texas 79999

RE: Franklin Hills Unit 2 Street Acceptance

Dear Mr. Soueidan:

All construction of public improvements for the above referenced subdivision have been completed in accordance to approved plans. We respectfully request the that the City of El Paso accept Franklin Hills Unit 2 for maintenance. Franklin Hills Unit 2, as shown on the enclosed Plat, includes the following streets and related storm water structures:

High Ridge Drive from Wind Ridge Drive to easterly limits of the subdivision;

Franklin Cove Place from High Ridge Dr. to Drainage Channel;

Franklin View Drive from Franklin Cove Pl. to the easterly limits of the subdivision;

Franklin Crest Drive from High Ridge Drive to the norther limits of the subdivision;

Franklin Summit Drive from the westerly cul-de-sac head to the easterly limits of the subdivision;

Franklin Nook Drive from Franklin Summit Drive to the northerly cul-de-sac head;

Franklin Red Drive from the Franklin Crest Drive to Franklin Hills Street;

Franklin Trail Drive from Franklin Summit Drive to Franklin Hills Street;

Franklin Vista Drive from Franklin Crest Drive to the easterly limits of subdivision;

Franklin Bluff Drive from Franklin Crest Drive to the easterly limits of subdivision;

Franklin Hills Street from the northerly limits of Franklin Hills Unit 3 to northerly limits of Unit 2.

The drainage channel, box culvert and related drainage structures from Sta.0+00 to Sta.17+10.48 including those within: the drainage easement between lots 3 & 4 Block 12; within the drainage easement between Lots 7 & 8 Block 17, and the drainage R.O.W. between Lots 7 & 8, Block 16.

Previously submitted for your use were the following: required submittals list, contractors/consultants list, monument certification letter, release of liens, utility release letters, testing reports, and mylar asbuilts.

We appreciate your assistance, if you have any questions or require additional information, please do not hesitate to call.



